

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS		INSPECTION/INSTALLATION ADDRESS		LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)	
Reg No:	210278	Name & Title:	ATIP Shesh	Name & Title:	
Company:	heating on demand	Address:	205 church st	Address:	
Address:	264 lonsdale drive		LONDON		
Postcode:	en2 7fd		EDMONTON	Postcode:	
Tel:	07904 656 447	Postcode:		Tel:	

	APPLIANCE DETAILS				FLUE TESTS				INSPECTION DETAILS									
	Location	Make and Model	Type	Flue Type OF/RS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance Visual Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1	Bedroom	VAillant Ecotec 624	BLN	1-S	25.7kw Yes	Yes	NA	0.009	0.007	Yes	Pass	Yes	Yes	Yes	Yes	Yes	Yes	Yes
2	Bedroom	VAillant Ecotec 637	BLN	1-S	39.4kw Yes	Yes	NA	0.008	0.006	Yes	Pass	Yes	Yes	Yes	Yes	Yes	Yes	Yes
3	Kitchen Area	- Silver Gas hob	4-hobs	F-L	20.4kw Yes	Yes	NA	NA	NA	NA	NA	NA	Yes	Yes	Yes	NO	NO	Yes
4	Kitchen Area	- Silver Gas hob	5-hobs	F-L	19.5kw Yes	Yes	NA	NA	NA	NA	NA	NA	Yes	Yes	Yes	NO	NO	Yes
5																		

For appliances not owned by the landlord the recorded 'Appliance Safe to Use' response is based on a visual check for obvious defects only

Gas Installation Satisfactory Visual Inspection: Yes No Emergency Control Accessible: Yes No

Pipework: Satisfactory Visual Inspection: Yes No Satisfactory Gas Tightness Test: Yes No Equipotential Bonding Satisfactory: Yes No

GIVE DETAILS OF ANY FAULTS		RECTIFICATION WORK CARRIED OUT	
1			
2			
3			
4			
5			

Audible CO Alarms: Approved CO Alarms Fitted: Yes No N/A Are CO Alarms in Date: Yes No N/A

Smoke Alarms Fitted: Yes No N/A

OTHER COMMENTS OR OBSERVATIONS

ISSUED BY (GAS ENGINEER)
 Print Name: Richie McLean Signed: [Signature]
 Licence No: 210278 Issue Date: 07-03-22

RECEIVED BY
 (Delete as applicable)
 Received By: _____ Tenant/Agent/Landlord/Home Owner
 Signed: _____ Print Name: _____